



Incorporated October 22, 1956

CITY OF SARATOGA

13777 FRUITVALE AVENUE • SARATOGA, CALIFORNIA 95070 • (408) 868-1200

COUNCIL MEMBERS:

Manny Cappello

Jill Hunter

Emily Lo

Howard Miller

Chuck Page

CITY OF SARATOGA, CALIFORNIA

ADDENDUM NO. 2

FOR

SARATOGA LIBRARY SOLAR PROJECT

Attached is Addendum No. 2 which consists of:

- This cover sheet.
- Addendum No. 2.

Each bidder must acknowledge receipt of this Addendum by making a note on the page 62 of the bid documents.

ADDENDUM No. 2

March 27, 2012

CITY OF SARATOGA

SARATOGA LIBRAY SOLAR PROJECT

Alternate location of Inverters/Combiners:

Attached is a schematic drawing showing alternate location for Combiner(s) and Inverter(s) and notes regarding the structural support of the equipment. The equipment, if proposed on the roof, must not be visible from the ground level.

Walkways – alternate scope of work:

Item No. 27 of Specifications, page 16 of 16 of Specifications.

The Contractor can select an option to remove existing wood shakes under the proposed array and three (3) feet around the array and replace the roof with asphalt composite shingle roof. If the Contractor selects this option, the new walkway is NOT necessary. The Contractor is responsible for installation of all flashing necessary to waterproof all transitions between the existing and new sections of the roof. All roof repairs to transition areas between the existing and new roof sections within five (5) years from the issuance of the Notice of Completion shall be responsibility of the Contractor. The color of the new roofing material shall match existing roof as much as possible. A sample tile of the new roofing material shall be submitted to the City for approval.

Production Guarantee:

Production Guarantee as described in item No. 1 of Overview in Specifications (page 1 and 2 of 16 of Specifications) is NOT required. There is no change in Item No. 23 – Data Acquisition System.


Bid opening – NO CHANGE:

Bid opening is scheduled for Thursday March 29, 2012 at 10:00 am in City of Saratoga City Hall located at 13777 Fruitvale Avenue, Saratoga, CA 95070

All the bid documents including this Addendum No. 2 are available for downloading from the City of Saratoga web site at www.saratoga.ca.us under What's New - Bids & RFPs <http://www.saratoga.ca.us/services/bids.asp>

Iveta Harvancik, Senior Engineer, City of Saratoga, (408) 868-1274, iharvancik@saratoga.ca.us

End of Addendum No. 2.



Notes:

1. Without dimensional and weight information of proposed equipment, it is not possible to confirm structural adequacy. Existing framing is unclear in this region. Arch. drawings imply 2x14's at 16" o.c. in this region.

Contractor to verify existing framing. If confirmed, then 2x14 @ 16" is likely adequate to support and anchor light-to medium-weight equipment.

2. Existing 14" TJI framing in this region. Framing likely adequate to support light- to medium-weight equipment. Direct lag drilling into TJI's is not acceptable. Additional structural blocking will be required between TJI joists for equip anchor lag screw attachments.